



cfo@vmc.gov.in



FORM B 13.3

## FIRE SAFETY CERTIFICATE RENEWAL (FSCR)

(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOVMC/2021/00005142  
FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOVMC/2021/00005142/R1

Date: 27/01/2025

Building Occupancy/Category: Educational (non-residential)

To,

Bharatiya Vidya Bhavan's Vallabhram Mehta Public S  
BHARATIYA VIDYA BHAVAN'S MAKARPURA TEEN RASTA VADODARA Vadodara MC 390009  
Fire Region: Vadodara MC  
Mobile No: 9974627446 Email ID: bhavansvadodara@gmail.com

This has reference to your Application No. 2024/00099357 dated 10/12/2024 for Fire Safety Certificate Renewal (FSCR) for the building/premise BHARATIYA VIDYA BHAVAN'S (name of the Building/ Project), as per below mentioned details:

1. TP Number:
2. FP Number:
3. Survey Number: 201
4. Village Name: VADODARA
5. Name of Block(s): BHARATIYA VIDYA BHAVANS

The building/premise was inspected on 27/01/2025 and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on 27/01/2025
2. Six monthly inspection was done on 27/01/2025

The Fire Safety Certificate is renewed for a period of **two (2)** years upto 27/01/2027 in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.



*Kishor Anish*

### Digitally Verified

Digitally verified by: Sandipkumar  
Fire Safety Officer - Advance (FSO-A)  
2021/000278

Date: 27/01/2025  
Time: 12:54 PM

**PRINCIPAL**  
BHARATIYA VIDYA BHAVAN'S  
VALLABHBRAM MEHTA PUBLIC SCHOOL,  
VADODARA-390009



FSCA/O/CFOVMC/2021/00005142/R1  
**HON. SECRETARY,**  
**BHARATIYA VIDYA BHAVAN'S**  
**VALLABHBRAM MEHTA PUBLIC SCHOOL**

This is a digitally verified certificate, hence a valid one. To validate authenticity of this certificate, scan the QR code or search the certificate details in the portal at [www.gujfiresafetycop.in](http://www.gujfiresafetycop.in).

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.



Scanned with OKEN Scanner